

WMBUS DATA FORMAT

TEMP/HUMIDITY/VOC DEVICE (FX-WMBUS-E-VOC)



Verify correct device and version

This document applies to the device FX-WMBUS-E-VOC with protocol version 1. There are two ways of finding out the protocol version of the device; either by looking at the label on the device or by looking at the data packets sent out by the device. See chapters **Protocol version in data packets** and **Protocol version in label** for more information.

Protocol version in data packets

If it is possible to check the information in the data packets sent out by the device, then the protocol version is included in the data field called *A-Field* with content *Protocol version*. For more information, see chapter **WMBUS-data format**.

Protocol version in label

The protocol version can be found on the label. An example of the label is shown in the figure below and the relevant information is described by LAS.00026462.43.01, where

- **Manufacturer code:** LAS
- **Serial number:** 00026462
- **Device type:** 43 (0x2B)
- **Protocol version:** 01 (0x01)



FX-WMBUS-E-VOC

LAS.00026462.43.01



www.fidelix.com

WMBUS-data format

Art nr.	LAN-WMBUS-E-VOC			
Version	1			
Information	Packet is sent every 90 seconds in T-mode.			
DR1	Temperature: Last measured value			
DR2	Temperature: Average last hour			
DR3	Temperature: Average last 24 hours			
DR4	Humidity: Last measured value			
DR5	Humidity: Average last hour			
DR6	Humidity: Average last 24 hours			
DR7	VOC: Last measured value			
DR8	VOC: Average last hour			
DR9	VOC: Average last 24 hours			
DR10	Version			
Byte No	Field Name	Content	Info	Byte data
1	L-Field	Length		
2	C-Field	SND-NR		0x44
3	M-Field	Meter Manufacturer code	LAS Example: 0001067	0x33
4	M-Field	Meter Manufacturer code		0x30
5	A-Field	Meter serial number (LSB)		0x67
6	A-Field	Meter serial number		0x00
7	A-Field	Meter serial number		0x01
8	A-Field	Meter serial number (MSB)		0x00
9	A-Field	Protocol version		0x01
10	A-Field	Meter type	VOC-sensor device	0x2B
11	CI-Field	Short header		0x7A
12	Access no.	Transmission counter	Example: 7	0x07
13	Status	Device status (error/alarms)	Refer to Table 1 for possible values	0x00
14	Configuration	Number of encrypted blocks	Example: 3	0x03
15	Configuration	Encryption		No encryption: 0x00 Encryption mode 5: 0x05
16	AES-Verify	Encryption Verification		0x2F
17	AES-Verify	Encryption Verification		0x2F
18	DR1	DIF	16-bit integer	0x02
19	DR1	VIF	External temperature 0.01°C	0x65
20	DR1	Value (LSB)	Example: 0x1122	0x22
21	DR1	Value (MSB)		0x11
22	DR2	DIF	16-bit integer + Storage 1	0x42 = Value OK 0x72 = Not enough values
23	DR2	VIF	External temperature 0.01°C	0x65
24	DR2	Value (LSB)	Example: 0x4365	0x65
25	DR2	Value (MSB)		0x43
26	DR3	DIF	16-bit integer	0x82 = Value OK 0xB2 = Not enough values
27	DR3	DIFE	Storage 2	0x01
28	DR3	VIF	External temperature 0.01°C	0x65
29	DR3	Value (LSB)	Example: 0x1122	0x22
30	DR3	Value (MSB)		0x11
31	DR4	DIF	16-bit integer	0x02
32	DR4	VIF	Extension table	0xFB
33	DR4	VIF	Relative humidity 0.1%RH	0x1A
34	DR4	Value (LSB)	Example: 0x1122	0x22
35	DR4	Value (MSB)		0x11
36	DR5	DIF	16-bit integer + Storage 1	0x42 = Value OK 0x72 = Not enough values
37	DR5	VIF	Extension table	0xFB
38	DR5	VIF	Relative humidity 0.1%RH	0x1A
39	DR5	Value (LSB)	Example: 0x1122	0x22
40	DR5	Value (MSB)		0x11
41	DR6	DIF	16-bit integer	0x82 = Value OK 0xB2 = Not enough values
42	DR6	DIFE	Storage 2	0x01
43	DR6	VIF	Extension table	0xFB
44	DR6	VIF	Relative humidity 0.1%RH	0x1A
45	DR6	Value (LSB)	Example: 0x1122	0x22
46	DR6	Value (MSB)		0x11
47	DR7	DIF	16-bit integer	0x02
48	DR7	VIF	Extension table	0xFD
49	DR7	VIF	Dimensionless	0x3A
50	DR7	Value (LSB)	Example: 0x1122	0x22
51	DR7	Value (MSB)		0x11

Linklayer

Networklayer

DATA blocks

52	DR8	DIF	16-bit integer + Storage 1	0x42 = Value OK 0x72 = Not enough values
53	DR8	VIF	Extension table	0xFD
54	DR8	VIF	Dimensionless	0x3A
55	DR8	Value (LSB)	Example: 0x2233	0x33
56	DR8	Value (MSB)		0x22
57	DR9	DIF	16-bit integer	0x82 = Value OK 0xB2 = Not enough values
58	DR9	DIFE	Storage 2	0x01
59	DR9	VIF	Extension table	0xFD
60	DR9	VIF	Dimensionless	0x3A
61	DR9	Value (LSB)	Example: 0x0102	0x02
62	DR9	Value (MSB)		0x01
63	DR10	DIF	16-bit integer	0x02
64	DR10	VIF	Extension table	0xFD
65	DR10	VIF	Version	0x0F
66	DR10	Value (LSB)	Example: 0x0004	0x04
67	DR10	Value (MSB)		0x00

Table 1: Status byte with errors and alerts

Bit	Info
0 (0x01)	X
1 (0x02)	X
2 (0x04)	Low battery
3 (0x08)	X
4 (0x10)	X
5 (0x20)	X
6 (0x40)	X
7 (0x80)	X